



Robust Control System

CheEng@TongjiU
Min Huang, PhD



Quiz

Find $H(s) = \frac{C(s)}{R(s)}$, $N(s) = \frac{C(s)}{D(s)}$ and sensitivity $s_K^{H(s)}$. What

have you found ?

$$H(s) = \frac{C(s)}{R(s)} = \frac{G_{c1}(s)G_{c2}(s)KG_0(s)}{1 + KG_{c2}(s)G_0(s)}$$

$$N(s) = \frac{C(s)}{D(s)} = \frac{1}{1 + KG_{c2}(s)G_0(s)}$$

$$S_K^{H(s)} = \frac{\frac{dH(s)}{dK}}{H(s)} = \frac{K}{H(s)} \frac{dH(s)}{dK}$$

$$= \frac{1}{1 + KG_{c2}(s)G_0(s)}$$

$$\frac{dH}{dK} = \frac{G_{c1}(s)G_{c2}(s)G_0(s)}{[1 + KG_{c2}(s)G_0(s)]^2}$$

Large K is good,
but how large can we have?
Need to consider stability !


Quiz

Construct a Root-locus plot for the system

$$H(s) = \frac{C(s)}{R(s)} = \frac{G_{c1}(s)G_{c2}(s)KG_0(s)}{1 + KG_{c2}(s)G_0(s)}$$

Set G_{c1} and G_{c2} equal 1, and

$$KG_0(s) = \frac{K(7 + s)}{s(1 + s)(5 + s)(20 + s)}$$



**How to find the complex conjugate roots with a given K ?
Do it now for $K = 142$.**

K	Damping ratio	Roots of characteristic equation
248	0.277	$-5.1640, -20.0649, -0.3856 \pm j1.3348$
142	0.444	$-5.0878, -20.0325, -0.4398 \pm j0.8875$
71	0.666	$-5.0456, -20.01629, -0.4691 \pm j0.5245$

- If we place two zeros at (or near) the desired complex, conjugate-loop poles, for example $-0.4398 \pm j0.8875$,
- set:

$$G_{c2}(s) = \frac{(s + 0.4398 + j0.8875)(s + 0.4398 - j0.8875)}{0.98}$$

- what will happen ?

- Simplify,


$$G_{c2}(s) = \frac{s^2 + 0.88s + 0.98}{0.98}$$

$$G_{c2}(s) = s^2 + 0.88s + 1$$

- Keeping $G_{c1}=1$,

$$KG_{c2}(s)G_0(s) = \frac{K(7 + s)(s^2 + 0.88s + 1)}{s(1 + s)(5 + s)(20 + s)}$$

K	Damping ratio	Roots of characteristic equation
248	0.548	$-6.3715, -47.3367, -0.4459 \pm j0.6814$
142	0.644	$-6.0358, -33.3566, -0.4538 \pm j0.5392$
71	0.808	$-5.6914, -26.5282, -0.4652 \pm j0.3387$



• Not to change the characteristic of the system, by,

• Setting,
$$G_{c1}(s) = \frac{1}{s^2 + 0.88s + 1}$$

